



CENTRUM STAVEBNÍHO INŽENÝRSTVÍ a.s.
(Building Engineering Centre, joint-stock company)
Workplace in ZLÍN, K Cihelně 304, 764 32 ZLÍN - Louky

issues to

Applicant: DRUTEX S.A
Ul. Leborska 31
77-100 Bytów, Poland

CERTIFICATE

No. CV - 08 - 0848/Z

Product: Plastic single-light window of five-chamber profile system made of GL SYSTEM with insulating glass unit

Manufacturer: See Applicant

Description:

Frame 50001 / reinforcements 250024, sash 50011, reinforcements 250024; inner and outer joint gasket SECIL 02, outer glazing gasket: SECIL 01, glazing bar 50924 with sealing; glazing - IGU: Guardian Clima Guard™ Premium 4 mm – spacer AHS 1556 020 Nirotec – tl. 16 mm, Argon – Float 4 mm; drainage and air intake in the glazing channel /sash/ 2x(28,5x3,8) mm; drainage of the joint gasket (or the frame) 3 entrance and outlet openings (29x4) mm, decompression (air intake) of the frame non-executed; all-periphery fittings MACO MULTI Trend, eight-point closure, window handle with catch; surface finishing: PVC with white colour.

Title of tested parameter	Testing method	Result
Thermal transmittance U_w	ČSN EN ISO 12567-1	1,3 W/(m ² .K)

This Certificate proves the conformity of above given product properties with the required standard values:

Fulfils the standard ČSN 73 0540, part 2
- for maximum required thermal transmittance

$$U_{N(w)} \leq 1,7 \text{ W/(m}^2 \cdot \text{K)}$$

Background documents: Test report No. 55/08. CSI, a.s. Zlín, AO 212

This Certificate applies only for a product which its specification is given in the test report in detail. It certifies only above given properties and neither implies nor substitutes certification in accordance with the Law No. 22/1997 Coll. on technical requirements for products.



Issue date: 6.6.2008
Valid till: 6.6.2010
Elaborated by: Ing. Nizar Al-Hajjar

RNDr. Josef Vrána, CSc.
head of workplace